



Independent Home Inspection
715 Waterbury Hill Road
LaGrangeville, NY 12540-

Matrix: Water

Client: [REDACTED]

Sample Location: [REDACTED]

Phone (845) 677-8805

This sample taken by Kenneth Nohai at 11:30:00 AM on 11/24/2024. . Point of collection: Kitchen Sink

Comprehensive Scan Report

Analytes	Results	Accredited Method	EPA Limits
Bacteria			
Total Coliform	Present	SOP #111 based on SM 9223B	0
E. Coli	Absent	SOP #111 based on SM 9223B	0
Mineral Chemistry			
Sodium	15.36 mg/L		No Limit
Potassium	0.60 mg/L		No Limit
Copper	0.01 mg/L		1.30 mg/L
Iron	0.01 mg/L		0.30 mg/L
Manganese	0.31 mg/L		0.05 mg/L
Magnesium	12.16 mg/L		No Limit
Calcium	100.36 mg/L		No Limit
Arsenic (Total)	Not Detected		0.010 mg/L
Lead	Not Detected		0.015 mg/L
pH	7.81 SU	SOP #101 based on SM 4500-HB	6.5 - 8.5 SU
Turbidity	0.27 N.T.U.	SOP #115 based on SM 2130B	No Limit
Color	0 C.U.		15.0 C.U.
Odor	Absent		3.0 T.O.N.
Conductivity	659.0 umhos	SOP #103 based on SM 2510B	No Limit
T.D.S.	395.4 mg/L		500.0 mg/L
Sediment	Absent		Present
Chlorine	Not Detected	SOP #114 based on SM 4500-CL-G	4.0 mg/L
Chloride	25.36 mg/L	SOP #125 based on EPA 6500	250.0 mg/L
Hardness	300.7 mg/L		No Limit
Nitrate as Nitrogen	Not Detected	SOP #125 based on EPA 6500	10.0 mg/L
Nitrite as Nitrogen	Not Detected	SOP #125 based on EPA 6500	1.0 mg/L
Ammonia as Nitrogen	Not Detected		No Limit
Sulfate	4.68 mg/L	SOP #125 based on EPA 6500	250.0 mg/L
Radiochemistry			
Radon in Water	Not Detected		.

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results. Not all analyses were conducted in accordance with Massachusetts Department of Environmental Protection certification standards.



Independent Home Inspection
715 Waterbury Hill Road
LaGrangeville, NY 12540-

Matrix: Water

Client: [REDACTED]

Sample Location: [REDACTED]

Phone (845) 677-8805

This sample taken by Kenneth Nohai at 11:30:00 AM on 11/24/2024. . Point of collection: Kitchen Sink

Comprehensive Scan Report

Analytes	Results	Accredited Method	EPA Limits
<i>Volatile Organics</i>			
Benzene	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Bromobenzene	Not Detected	SOP #107 based on EPA 524.2	-
Bromochloromethane	Not Detected	SOP #107 based on EPA 524.2	-
Bromodichloromethane	Not Detected	SOP #107 based on EPA 524.2	-
Bromoform	Not Detected	SOP #107 based on EPA 524.2	-
Bromomethane	Not Detected	SOP #107 based on EPA 524.2	-
n-Butylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
sec-Butylbenzene	Not Detected	SOP #107 based on EPA 524.2	No Limit
tert-Butylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
Carbon-Tetrachloride	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Dibromochloromethane	Not Detected	SOP #107 based on EPA 524.2	-
Chloroethane	Not Detected	SOP #107 based on EPA 524.2	-
Chloroform	Not Detected	SOP #107 based on EPA 524.2	-
Chloromethane	Not Detected	SOP #107 based on EPA 524.2	-
1,2-Chlorotoluene	Not Detected	SOP #107 based on EPA 524.2	-
1,4-Chlorotoluene	Not Detected	SOP #107 based on EPA 524.2	-
1,2-Dibromo-3-chloropropane	Not Detected		0.2 ug/L
Dibromomethane	Not Detected	SOP #107 based on EPA 524.2	-
1,2-Dibromoethane	Not Detected		-
1,3-Dichlorobenzene	Not Detected	SOP #107 based on EPA 524.2	-
1,2-Dichlorobenzene	Not Detected	SOP #107 based on EPA 524.2	600.0 ug/L
1,4-Dichlorobenzene	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Dichlorodifluoromethane	Not Detected	SOP #107 based on EPA 524.2	-
1,1-Dichloroethane	Not Detected	SOP #107 based on EPA 524.2	-
1,2-Dichloroethane	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
1,1-Dichloroethylene	Not Detected	SOP #107 based on EPA 524.2	7.0 ug/L
cis-1,2-Dichloroethene	Not Detected	SOP #107 based on EPA 524.2	70.0 ug/L
trans-1,2-Dichloroethene	Not Detected		100.0 ug/L
1,2-Dichloropropane	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
1,3-Dichloropropane	Not Detected	SOP #107 based on EPA 524.2	-
2,2-Dichloropropane	Not Detected	SOP #107 based on EPA 524.2	-

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results. Not all analyses were conducted in accordance with Massachusetts Department of Environmental Protection certification standards.



Independent Home Inspection
715 Waterbury Hill Road
LaGrangeville, NY 12540-

Matrix: Water

Client: [REDACTED]

Sample Location: [REDACTED]

Phone (845) 677-8805

This sample taken by Kenneth Nohai at 11:30:00 AM on 11/24/2024. . Point of collection: Kitchen Sink

Comprehensive Scan Report

Analytes	Results	Accredited Method	EPA Limits
1,1-Dichloropropene	Not Detected	SOP #107 based on EPA 524.2	-
1,3-Dichloropropene	Not Detected	SOP #107 based on EPA 524.2	-
trans-1,3-Dichloropropene	Not Detected	SOP #107 based on EPA 524.2	No Limit
Ethylbenzene	Not Detected	SOP #107 based on EPA 524.2	700.0 ug/L
Trichlorofluoromethane	Not Detected	SOP #107 based on EPA 524.2	No Limit
Hexachlorobutadiene	Not Detected	SOP #107 based on EPA 524.2	-
Isopropylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
Methyl-t-Butyl Ether (MTBE)	Not Detected	SOP #107 based on EPA 524.2	70.0 ug/L
p-Isopropyltoluene	Not Detected	SOP #107 based on EPA 524.2	-
Methylene Chloride	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Monochlorobenzene	Not Detected	SOP #107 based on EPA 524.2	100.0 ug/L
Napthalene	Not Detected	SOP #107 based on EPA 524.2	-
n-Propylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
Styrene	Not Detected	SOP #107 based on EPA 524.2	100.0 ug/L
1,1,1,2-Tetrachloroethane	Not Detected	SOP #107 based on EPA 524.2	-
1,1,1,2,2-Tetrachloroethane	Not Detected	SOP #107 based on EPA 524.2	-
Tetrachloroethylene	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Toluene	Not Detected	SOP #107 based on EPA 524.2	1000.0 ug/L
1,2,3-Trichlorobenzene	Not Detected	SOP #107 based on EPA 524.2	-
1,2,4-Trichlorobenzene	Not Detected	SOP #107 based on EPA 524.2	70.0 ug/L
1,1,1-Trichloroethane	Not Detected	SOP #107 based on EPA 524.2	200.0 ug/L
1,1,2-Trichloroethane	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
Trichloroethylene	Not Detected	SOP #107 based on EPA 524.2	5.0 ug/L
1,2,3-Trichloropropane	Not Detected	SOP #107 based on EPA 524.2	-
1,2,4-Trimethylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
1,3,5-Trimethylbenzene	Not Detected	SOP #107 based on EPA 524.2	-
Vinyl Chloride	Not Detected	SOP #107 based on EPA 524.2	2.0 ug/L
o-Xylene	Not Detected	SOP #107 based on EPA 524.2	T. Xylenes 10K ug/
m+p Xylenes	Not Detected	SOP #107 based on EPA 524.2	T. Xylenes 10K ug/

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results. Not all analyses were conducted in accordance with Massachusetts Department of Environmental Protection certification standards.